

Energy performance certificate (EPC)

23 Cromwell Road BELFAST BT7 1JW	Energy rating	Valid until: 24 July 2034
	G	Certificate number: 2856-3040-2203-1654-3200

Property type	Mid-terrace house
Total floor area	155 square metres

Energy rating and score

This property's energy rating is G. It has the potential to be E.


[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D
the average energy score is 60



Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, no insulation (assumed)	Very poor
Window	Mostly double glazing	Poor
Main heating	Room heaters, electric	Very poor
Main heating control	No thermostatic control of room temperature	Poor
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Low energy lighting in 14% of fixed outlets	Poor
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 622 kilowatt hours per square metre (kWh/m²).

How this affects your energy bills

An average household would need to spend **£9,009 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £4,305 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is G. It has the potential to be F.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces **6 tonnes of CO₂**

This property produces **16.0 tonnes of CO₂**

This property's potential production **14.0 tonnes of CO₂**

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Insulate hot water cylinder with 80 mm jacket	£15 - £30	£552
2. High heat retention storage heaters	£3,200 - £4,800	£3,752
3. Floor insulation (solid floor)	£4,000 - £6,000	£97
4. Solar water heating	£4,000 - £6,000	£128
5. Internal wall insulation	£4,000 - £14,000	£915
6. Solar photovoltaic panels	£3,500 - £5,500	£536

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Carleen Branagan
Telephone	07756 897853
Email	carleenbranagan@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/020444
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	25 July 2024
Date of certificate	25 July 2024
Type of assessment	RdSAP