
Find an energy certificate (/)

English | Cymraeg

## **Energy performance certificate** (EPC)




Property type	Semi-detached house
Total floor area	120 square metres

### **Energy rating and score**

This property's energy rating is D. It has the potential to be C.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

# Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature Description		Rating
Wall	Cavity wall, filled cavity	Average
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof Pitched, 300 mm loft insulation Very go		Very good
Roof	Flat, insulated (assumed)	Average

Feature Description		Rating
Roof	Pitched, insulated (assumed)	
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer and at least two room thermostats Good	
Hot water	From main system Good	
Lighting	Low energy lighting in 19% of fixed outlets Poor	
Floor	Solid, no insulation (assumed) N/A	
Floor	Solid, insulated (assumed) N/A	
Secondary heating	Room heaters, coal	N/A

### Primary energy use

The primary energy use for this property per year is 212 kilowatt hours per square metre (kWh/m2).

About primary energy use

### How this affects your energy bills

An average household would need to spend £1,021 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £111 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2019** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Impact on the environment

This property's environmental impact rating is D. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

### **Carbon emissions**

An average household produces	6 tonnes of CO2
This property produces	5.3 tonnes of CO2

### This property's potential production

4.8 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

### Steps you could take to save energy

Do I need to follow these steps in order?

### Step 1: Low energy lighting

Typical installation cost	£85
Typical yearly saving	£56
Potential rating after completing step 1	69 C

## Step 2: Heating controls (time and temperature zone control)

Heating controls (zone control)

Typical installation cost	£350 - £450
Typical yearly saving	£56
Potential rating after completing steps 1 and 2	70 C

### Step 3: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£30
Potential rating after completing steps 1 to 3	71 C

### Step 4: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£310

### Potential rating after completing steps 1 to 4

80 C

### Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Patricia Best
Telephone	07788108883
Email	patricia@bestpropertysurveys.com

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO032003
Telephone	0330 124 9660
Email	certification@stroma.com

### About this assessment

Assessor's declaration	No related party
Date of assessment	29 August 2019
Date of certificate	29 August 2019
Type of assessment	► RdSAP

### Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <a href="mailto:mhclg.digital-services@communities.gov.uk">mhclg.digital-services@communities.gov.uk</a> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number 9700-0521-6750-7610-5922 (/energy-

certificate/9700-0521-6750-7610-5922)

**Expired on** 19 September 2020



Help (/help) Accessibility (/accessibility-statement) Cookies (/cookies)

Give feedback (https://forms.office.com/e/KX25htGMX5)

Service performance (/service-performance)

#### **OGL**

All content is available under the <u>Open Government</u> <u>Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/)</u>, except where otherwise stated



© Crown copyright (https://www.nationalarchives.gov.uk/information-management/reusing-public-sector-information/uk-government-licensing-framework/crown-copyright/)